## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

LISTING No.

7315-0410:167

Page 1 of 1

CATEGORY:

**Power Units** 

LISTEE:

Hochiki America, 7051 Village Dr., Suite 100, Buena Park, CA 90621-2268

Contact: Bob Misiuk (714) 670-3251 FAX (714) 690-7890

DESIGN:

Models FN-1024ULX, FN-300ULX and FN-400ULX power supply units may be followed by -G, -R, -C, or -B. Models FN-300ULX series are designed to charge sealed lead acid type rechargeable batteries. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:

115 VAC input, 12 or 24 VDC output

INSTALLATION:

In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For fire alarm use, the standby batteries must provide 24 hours standby power during power loss.

MARKING:

Listee's name, model number, electrical rating, and UL label.

APPROVAL:

Listed as power supply units for use with separately listed compatible fire alarm control units to provide power for door holders, door strikes or similar devices. Refer to listee's

Installation Instruction Manual for details.

NOTE:

Not suitable for fire alarm indicating devices.

XLF:

7315-1335:100

05-03-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 12, 2006** 

Listing Expires June 30, 2007

Authorized By:

**DIANE K. AREND**, Senior Deputy

Program Manager